

# COMPUTER AIDED EMC ANALYSIS FOR ELECTRONIC SYSTEMS

## SEMCAP—VERSION 8

### INTRODUCTION

SEMCAP (Specification and Electromagnetic Compatibility Analysis Program) is a large scale computer program for intrasystem EMC analysis, and has been in use since 1968, when it was developed as a spacecraft oriented intrasystem analysis program for NASA's Manned Space Center (later Johnson Space Center) in Houston, Texas. Numerous articles\* have been written about the subject of intrasystem compatibility and about the original version of SEMCAP. Basically, this program performs an EMC analysis between modeled interference generators and modeled interference receptors for various interference transfer functions. The generators and receptors are modeled in terms of their electrical and physical parameters. The system's physical characteristics are also modeled so that transfer functions can be computed. The computer calculates the spectrum of the generator circuits and transfers the energy via the transfer function to the receptor terminals. The received spectrum is limited by the receptor bandwidth and integrated over the complete frequency range from 10 Hz to 10 GHz (or higher, at the user's option). The integral then represents the voltage available at the receptor terminals. This received voltage is compared to the threshold of the particular circuits to determine compatibility status. In addition, the computer stores the voltage received from a particular generator and proceeds through the complete generator list until the contribution of each generator is determined. These contributions are summed to determine if the receptor is compatible with the sum of all generating sources modeled. The purpose of this article is to acquaint the EMC community with the latest version of SEMCAP (Version 8), which has considerably more capabilities than earlier versions.

### BACKGROUND

Through years of usage, many improvements and added capabilities have been incorporated into SEMCAP in order to make it more responsive to the needs of the user and to new engineering problems which had not been foreseen when it was first developed.

By 1972, Version 6 (V6) of SEMCAP was operational and in use on the B1 Bomber program. Because of the greater complexity of the wiring geometry of an airplane versus most spacecraft, improvements were necessary to facilitate the handling of the input data. By late 1972, Version 7 (V7) was operational, and by 1974, Version 7.4 was in use.

The V7 programs have been used on many military and scientific satellites and by a number of organizations including TRW, JPL, Rockwell International, ERNO, and Hawker-Siddeley.

The results of the continual work done on SEMCAP have led to statistically predictable error distributions, shown in Figure 1.




Figure 1. SEMCAP Error Distribution Curve

### NOTES:

- (1)  $\text{ERROR (dB)} = 20 \log \frac{\text{VOLTS PREDICTED}}{\text{VOLTS MEASURED}}$
- (2)  $\text{MEAN ERROR } (\mu) \approx 9 \text{ dB}$
- (3)  $\text{STANDARD DEVIATION } (\sigma) = 10 \text{ dB}$
- (4)  $\mu$  and  $\sigma$  are based on a sample of 81 data points.
- (5) Each data point is an actual voltage measurement made during spacecraft system level EMC tests on circuits for which SEMCAP predicted voltages were in excess of allowable conducted noise levels.

### DEVELOPMENT OF VERSION 8

In the course of using SEMCAP for large problems, the need arose to solve smaller problems on a quick turnaround basis, so SEMCAP-T was developed. The favorable response to this on-line-terminal version of SEMCAP led to the development of a remote terminal version of the batch SEMCAP, and eventually to Version 8 (V8). During the conceptual stages of the V8 development, an opportunity was seen to make additional improvements to the program. In brief, these data improvements are as follows:

- Free form data input
- Data entry by cards or by timeshare terminal
- Data storage on permanent disk files or tape
- The limit of 240 generators and 240 receptors has been removed
- The number of harness segment lengths and map elements has been increased from 120 to 240
- Larger geometry matrices can be accommodated
- New diagnostic messages have been added for more thorough data checking
- Mnemonics, instead of model numbers, are used for model types
- Some improvements have been made in some transfer functions
- The storage for subsystem and circuit names has been increased from 24 to 40 characters
- There will be a decrease in the amount of core storage and CPU time in some cases
- Faster job turnaround can be expected when using remote batch job submission

In order to facilitate the use of V8 for problems originally defined for V7, a conversion program has been written (CNV78) to convert V7 data decks to V8 deck or disk files with almost no manual intervention. This conversion program has been used successfully on two major spacecraft analyses (HEAO and DSCS II) originally defined for V7.

\*Articles by A.K. Thomas, W.R. Johnson, and J.A. Spagon in the 1968 IEEE Symposium Record, and in the 1969 IEEE Symposium Records, and by J.A. Spagon in the 1976 IEEE Symposium Records, and in previous issues of ITEM.

## PRESENT CAPABILITIES OF SEMCAP VERSION 8

SEMCAP was developed to perform EMC analyses of spacecraft, where the major problems are in the area of wire-to-wire coupling in complex cable harnesses. Antenna to antenna radiation on most satellites does not represent a serious analysis problem because, unlike an airplane, there are few antennas on most satellites, and these usually operate in the GHz frequency range. Therefore, the emphasis was placed on what happens inside the spacecraft. Consequently, SEMCAP models are virtually unconstrained by the complexity of cable harnesses regardless of the number of different wires or types of wires used, the number of harness segments, unequal spacing of wires in the harness, different heights above ground, different pigtail lengths, etc. A unique feature of SEMCAP is that the model may simultaneously define a large number of different separation distances between wires in the same harness, or between wires in different harnesses. The metric system is used throughout. In addition to handling the effects of shielded wires, SEMCAP simultaneously can deal with the effects of group shields, bulkhead shielding, various values of ground return resistances, various values of common return paths, etc.

However, because it is recognized that not all problems deal with wire-to-wire coupling, a flexible method was developed for modeling antenna to antenna, antenna to wire, and field to wire coupling. This method requires definition of the field rather than definition of typical antenna parameters. In fact, the antenna coupling capability of SEMCAP has been used very little because of the nature of the analytical problems to which it has been addressed. On the other hand, coupling from external fields originating from arc discharges and EMP has been analyzed using the E and H-field models. A feature of this flexibility is that any number of various internal and external fields can be modeled simultaneously, in either the time or frequency domains, and a large number of different structural shielding characteristics can be modeled simultaneously, with the shielding factors being either constant or variable as a function of frequency.

Another unique feature of SEMCAP is that it generates its own frequency base using as many points as necessary to define the spectrums, and has a standard frequency base of 1801 points which are logarithmically spaced to give 1% resolution. On the other hand, if the user wishes to select frequencies as in frequency amplitude pairs, he is virtually unlimited as to the number he may use.

SEMCAP models for generators are described in either the time or frequency domains. In the time domain, it accepts models for sinewaves, single pulses, pulse trains, and ramp steps. In the frequency domain, there is no practical limit to the number of frequency amplitude pairs that may be used. Voltage sources and current sources are defined independently. E and H-field sources are derived from the voltage and current sources, or may be entered independently, at the user's option. Filters may be used for each source and may be defined in either the frequency domain or by standard parameters such as cutoff frequency, slope, inband insertion loss, etc. Two filters may be cascaded for each source. The use of generator filters is optional, and in practice is used infrequently.

SEMCAP models for receptors are modeled as voltage thresholds combined with a frequency response curve. This allows a reasonably accurate representation of both analog and digital (or bi-level) circuits. The frequency response

curve can be defined in the frequency domain or by standard filter parameters. If desired, two filters can be cascaded for each receptor.

Because SEMCAP does not assume compatibility except within a black box, all generators are played against all receptors. As stated previously, there is no actual limit as to the number of generators and the number of receptors, although there are practical limits based on engineering time and computer time. Figure 2 shows the actual amount of CPU time as a function of G-R interactions for a CDC 6600 computer. Each interaction is called a "cell" in the G-R matrix. For example, an analysis of 100 generators and 100 receptors would result in a 10000 cell matrix, and would use between 500 and 600 CPU seconds.

The standard printout of a SEMCAP run shows, in addition to all the input data, a list of all the models, the integrated voltage received and margin for each generator-receptor interaction (including a breakdown by coupling mode, i.e., capacitive, inductive, E-field, H-field), the total voltage received and margin for each receptor versus all generators, and a compatibility matrix of all receptors and generators coded to identify ranges of margins. This last item is useful in providing a "quick look" at the results of an analysis.




Figure 2. SEMCAP Running Time Matrix Size versus CPU Seconds

## CONCLUSION

The development of SEMCAP V8 provides an enhanced version of a proven system level EMC analysis program which has been successfully used for many years by a number of well known aerospace organizations.

---

*The above material was reprinted with permission of TRW Defense and Space Systems Group.*