

CABLES AND CONNECTORS

INTRODUCTION

The electrical and mechanical designer spends much of his interference control efforts in the design of components without due regard to interconnecting cables and harnesses. The mechanical engineer designs the case or chassis seams with RF gasketing material, controls the machining and finishes of mating surfaces, covers holes with screening or honeycomb cells, and applies other mechanical controls. The electrical engineer specifies the power line filters, designs the grounding system, adds the transient noise suppressors and protectors, specifies the internal harnessing configuration, selects the connectors, and provides other electrical controls. However, unless the component is designed to operate independently from all other components or equipment, such as T.V., oscilloscope, radio, etc., the harness and cable configuration is delegated to subsystem and system engineers. Thus, the component design engineers only do half of the job.

Cable and harness configurations are critical in the component design to reduce the propagation of electrical noise (EMI) and its effects. The best electronic box, shielded enclosure or shielded room can always be compromised by poorly designed interconnecting cables. Cables provide a convenient path by which electrical noise is conducted out of the enclosure and then radiates or couples to adjacent wiring and equipment. The reverse process also occurs with external noise pick-up on cables being conducted into a well-shielded container. The filtering of the interconnecting lines does not always solve the problem. Lines which conduct clock pulses, digital signals, video signals, etc., cannot tolerate filters which affect the signals. These signals also appear as noise to other circuits when coupling to other lines occurs.

Systems engineers treat interconnecting harnessing very seriously in respect to noise control and electromagnetic compatibility. They realize that crosstalk is a real everyday problem, and intentional system radiation can have back-door effects if it is allowed to get into system wiring. This problem is not limited to military applications or systems. It can occur in the home, industrial plant, in office buildings, scientific centers, hospitals, automobiles, aircraft, as well as electronic laboratories. A car radio can be jammed by electrical noise radiation from unsuppressed truck ignition systems. Noise from the fluorescent lights, razor, vacuum cleaner, etc., interferes with T.V. and radio reception. Computers are extremely vulnerable to the coupling of transients generated by air-conditioners or time-clocks. In the hospital, patient monitors are disturbed by the magnetic fields emitted by power lines, heating blankets and other electronic equipment. Electric typewriters and other office machines can make communications nearly impossible. Electronic fly killers have been known to affect aircraft navigational equipment. In all of these examples, the method of radiation and pick-up of the electrical noise is through cables. The primary means of protecting electro-explosive devices is through the design of its cables.

CABLE SEPARATION

The coupling of signals and noise between wires and cables is a function of the distance between cables. Thus, it is most advantageous to categorize the various types of cable signals and to provide maximum separation between them. This is not always easy to accomplish, especially on space vehicles, or in complex electronic facilities where there are numerous cables and harness restrained by limited cable troughs. It also becomes a problem when wires of different categories share the same cable connector. However, an attempt should be made to provide whatever separation is practical. The following categories are illustrative only, and are usually modified to match the partial line voltages, signal levels and frequencies:

a. Category P, Power:

1. 115 volts and 240 volts single phase and three phase to motors, transformers, blowers, etc.
2. Control wiring which includes relay logic, stepping switches, indicator light circuits (incandescent), etc.
3. RF power, primarily transmitter outputs.

b. Category S, Sensitive Wiring:

This category includes moderately susceptible circuitry which is easily protected such as limited bandwidth audio amplifiers, input medium-level wide bandwidth video lines, properly designed digital computer input circuitry, clean dc power, etc.

c. Category VS, Susceptible Wiring:

This includes very sensitive circuitry such as a servo null circuit working to a null level of less than 100 microvolts, electro-explosive devices, high-impedance, low-level high-accuracy sensor circuitry (such as 10 millivolt, 10,000 ohm, and 0.5 percent accuracy), and antenna input circuitry.

As an aid, these three categories of wires might have an identifying color for ease in wiring and identification. The three categories should be run separately via different routing and should cross at right angles.

COUPLING MECHANISM

The physical model for analyzing the coupling between cables is that two or more cables run parallel. The coupling may be expressed in terms of the transfer impedance. The transfer impedance can be defined as the ratio of the voltage appearing between the conductors of the second cable to the current applied at the first. At low frequencies, i.e., those frequencies for which the total length of one is short compared to the wavelength (these are defined as those cables shorter than one-sixteenth wavelength), the current and voltage along the cable may be considered to be constant; therefore, it does not matter at which end of the cable the current or voltage is measured. At higher frequencies, standing waves on the cables must be taken into account if the cables are not terminated in their characteristic impedances.




Figure 1. Voltage Induced in a Loop

Transfer Impedance

The transfer impedance is clearly dependent upon the impedances terminating between the source and the susceptible cable. It will depend upon both magnetic and capacitive coupling effects. At low frequencies capacitive coupling is easily prevented by placing one or both of the cables in metallic shields. If the concern is with individual sensors in a cable, this shielding will not be possible, and both magnetic and capacitive coupling will be significant.

Magnetic Coupling

Magnetic coupling is most noticeable as a contributor to interference when the cables are terminated with low impedances at each end. Interference voltages are induced into a wire by flux linkages. The source of interference will be a generator of magnetic flux which may be a relay coil, transformer, solenoid, or just another current-carrying wire. The voltage induced in a loop by an adjacent wire of infinite length carrying current as illustrated in Figure 1 will be

$$E = (3.19 \times 10^{-8}) fLI \ln \frac{r_2}{r_1}$$

where

f = frequency, Hertz

L = length, inches

I = current, amperes

E = induced voltage, volts

r_1 and r_2 = loop distance, inches

If the susceptible loop is at an angle to the interference source, the following holds true. Figure 2 illustrates a source loop coupled to a sensitive wire loop.

$$E = (1.595 \times 10^{-8}) fLI \left[\ln \left(\frac{R_1^2 + W^2 + 2R_1 W \cos \theta}{R_1^2 + W^2 - 2R_1 W \cos \theta} \right) - \ln \left(\frac{R_2^2 + W^2 + 2R_2 W \cos \phi}{R_2^2 + W^2 - 2R_2 W \cos \phi} \right) \right]$$

The induced voltage increases with an increase in frequency, source current, and length of closed loop. The induced voltage also increases with effective area enclosed by the pick-up loop and will affect circuits by driving current through the impedances in the pick-up loop and its loads. For low frequencies, the impedance of the pick-up loop will consist primarily of wire resistance, and maximum power will be delivered to a load of low resistance. It should be assumed that the source circuit is a low impedance circuit since the most significant interference will result from a

high current source. The voltage delivered to the circuits attached to the pick-up loops will rise to half the induced voltage as the load impedance in the pick-up loops rises to match the driving impedance due to the coupling. As the load impedance rises from this point, the voltage at the circuit loads will rise to the full induced voltage as a maximum.

Capacitive Coupling

In long cable runs, an appreciable capacitance will most likely exist between adjacent wires and from each wire to ground or shield and capacitance will exist at connectors and associated wiring. The voltage induced into one wire from an adjacent wire is a function of these capacities. Figure 3 illustrates one model for the capacitive coupling in a cable. The interfering voltage, (E_o) couples through stray capacity (C_c) to produce a voltage (E_x) on the adjacent cable. The interfering cable and the adjacent cable have stray capacities to ground (C_a and C_b). Each cable has its system loads (Z_1 , Z_2 , Z_3 , and Z_4) across which the stray capacities appear. If cable load impedances are high, the frequency spectra of voltages (E_o) and (E_x) may be affected by (C_a) and (C_b). The voltage division ratio will be

$$\frac{E_x}{E_o} = \frac{Z_x Z_b / (Z_x + Z_b)}{Z_c + Z_x Z_b / (Z_x + Z_b)}$$

If Z_x is a high resistance load

$$\frac{E_x}{E_o} = \frac{C_c}{C_c + C_b} \sqrt{\frac{R_x^2}{R_x^2 + [\frac{1}{2}\pi f(C_c + C_b)]^2}}$$




Figure 2. Susceptible Loop at an Angle




Figure 3. Capacitance Coupling in a Cable




Figure 4. Frequency Versus Voltage Coupling in Wires

At high frequencies (rf), any open-ended wire should be given careful attention to determine if it is a pick-up point for high frequency excitation. Since small stray capacities provide effective coupling to a high impedance point, wires can frequently be excited when they are attached to vacant connector pins or open switch contacts. At a quarter wavelength distance, such open wires will be carrying maximum current and can readily couple into other wiring or circuits by the fields generated. An open wire will represent an effective antenna in the presence of electromagnetic fields. High radio frequencies are readily coupled into power wiring either magnetically or electrically, depending upon the standing wave which may be excited in the power wiring at the coupling point.

Figure 4 illustrates the frequency versus voltage coupling in adjacent wires and the function of their separation. Figure 5 shows the typical capacitance which exists for various configurations of shielded AN wires.

Not all connectors are designed to preclude the entry of RF energy. Each connector surface represents an impedance discontinuity of the cable shield. Even though there is mechanical contact with the shield through the outer mating section of the connector, a good RF connection is not assured. Radio frequency energy could enter at this point and cause a hazardous situation. A good connector is one in which the shielding effectiveness of the mated connector equals or exceeds that of an equal length of the cable utilized in the circuit. If the effectiveness of cable shields is to be maintained, the cable shield must be properly terminated. In an otherwise adequately shielded enclosure, RF currents that are conducted along the shields will be coupled to the system wiring from the point of improper cable termination.

In a properly terminated shield, such as when a Glenair backshell adaptor is used, the entire periphery of the shield is grounded to a low impedance reference, minimizing any RF potentials at the service of the termination. The use of epoxy or other synthetic conducting material has been found to be unacceptable for bonding in this situation.

IMPORTANT FACTORS

Solving cable shielding problems must take into consideration all variables of any particular case. These variables include:

1. the impedance of the radiating device
2. the impedance of the susceptibility device or circuit
3. the frequency range of the interference signal relative to the desired signal
4. the levels of the interference relative to the desired signals
5. the length of the transmission line.

Proper shielding, or other cable treatment techniques, and proper grounding cannot be effective unless all these variables are carefully considered for the particular case under study.

Although the theory of shielding cables and that of cable coupling and radiation may be interesting, many engineers are just interested in shielding and protecting the cables sufficiently adequate to do the job. The following design notes are provided to help streamline the process:

1. Determine the type of fields which are to be attenuated.
Electric Fields (electrostatic coupling)
Magnetic Fields (inductive coupling)
RF Fields (radiation)
2. Determine the types of shielding material that is required and the number of layers. (This relates directly to the amount of attenuation required.)
Tin-coated Braid
Hipernon (high permeability)
Conduit
3. Identify special purpose applications.
(FED-STD-222 and other FED/MIL/DCA Requirements)
4. Determine the type of shield termination desired. (360° peripheral terminations are best for most applications.)
5. Select the connector and back shell adaptor which best suits your requirements and provides good electrical grounding.

REFERENCES

When you have cabling problems, your best bet is to call the technical representatives of the advertisers in *ITEM* or others listed in the Sales Office Directory. If you want depth in the subject, the IEEE Transactions on Electromagnetic Compatibility provides an excellent source of information. The following papers appear in these *Transactions*, as noted:

1. "Shielding Tests for Cables and Small Enclosures in the 1 to 10 GHz Range"—W. Jarva—February 1970.
2. "Magnetic Fields of Twisted-Wire Pairs"—S. Shenfeld—November 1969.
3. "Effects of Partial Shields on Transmission Lines at Low Frequencies"—N. Farhot, Y. Loh, & R. Showers—March 1968.

TYPE	ONE WIRE SHIELDED				TWO WIRE SHIELDED				THREE WIRE SHIELDED		ONE WIRE DOUBLE SHIELDED	
CONFIGURATION												
WIRE SIZE	16	18	20	22	16	18	20	22	20	22	22	22
CONDUCTOR TO SHIELD pf / ft	89	91	74	98	68	65	64	62.5	60	52	98	340
					(EITHER CONDUCTOR TO SHIELD)				(ANY CONDUCTOR TO SHIELD)		(CONDUCTOR TO INNER SHIELD)	(INNER SHIELD TO OUTER SHIELD)
CONDUCTOR TO CONDUCTOR pf / ft					42	39.5	38	36.5	36	30		

Figure 5. Capacitance of Various Shielded AN Wires

4. "Magnetic Field Pick-up by Flexible Braid Coaxial Cables"—J. Bridges and R. Zalewski—March 1968.
 5. "Measurement of RF Leakage in Multipin Electrical Connectors"—F. Schor—March 1968.
 6. "Coupling Between Open and Shielded Wire Lines Over a Ground Plane"—R. Mohr—September 1967.
 7. "EMC of High Density Wiring Installations by Design or Retrofit"—W.D. McKerchar—March 1965.
 8. "Coupling Between Lines at High Frequencies"—R.J. Mohr—December 1967.
 9. "Analysis of Cable-Coupled Interference"—Greenstein & Tobin—March 1963.
 10. "Leakage of EMI Along Stationary Conductors Passing Through Conducting Walls"—Lombardine : Goldhirsh—March 1963.
 11. "Wiring of Data Systems for Minimum Noise"—J.V. White—March 1963.
 12. "Predicting Magnetic Fields From a Twisted Pair Cable"—Moser & Spencer—September 1968.
 13. "Anti-Interference Wires, Cables and Filters"—F. Mayer—September 1966.
 14. "Shield Grounding Effectiveness in Interference Reduction in the 50 Hz to 15 KHz Frequency Region"—McDonald & Taylor—March 1966.
 15. "Modeling of Fields Produced by Currents on Power Supply Wiring"—R.M. Showers—November 1971.
 16. "A Model for Currents and Voltages Induced Within Long Transmission Cables by an Electromagnetic Wave"—Bates & Hawley—November 1971.
 17. "Crosstalk on Cables: A Communication Theoretic Approach"—R.L. Swarts—May 1972.
 18. "Transmission Line Coupled to a Cylinder in an Incident Field"—King & Harrison—August 1972.
 19. "Excitation of a Coaxial Line Through a Transverse Slot"—Harrison & King—November, 1972.
 20. "Calculation of Magnetic Fields due to Line Currents"—S. Sabaroff—May, 1973.
 21. "Response of a Terminated Transmission Line Excited by a Plane Wave Field for Arbitrary Angles of Incidence"—C.W. Harrison & C.D. Taylor—Aug. 1973.
 22. "On the Excitation of a Coaxial Line by an Incident Field Propagating Through a Small Aperture in the Sheath"—C.W. Harrison & C.D. Taylor—Aug. 1973.
 23. "Terminal Response of Braided-Shield Cables to External Monochromatic Electromagnetic Fields"—S. Frankel—Feb. 1974.
 24. "Cable Shielding Effectiveness Testing"—E.D. Knowles & L.W. Olsen—Feb. 1974.
- 1968 IEEE EMC Symposium Record**
- "Internal Voltages and Currents in Solid Shielded Cables"—Vance & Nanevicz
 - "Common Mode Coupling Matrices"—T.H. Herring
 - "Coupling Between Open Wires Over a Ground Plane"—R. Mohr
 - "Penetration of Coaxial Cables by Transient Fields"—Miller and Torelios
- 1967 IEEE EMC Symposium Record**
- "RFI Shielding with Conductive Pressure—Sensitive Adhesive Tapes"—Olyphant & Dahlen
 - "Resonance Properties of the Shield of a Coaxial Cable Over a Ground Plane"—DeMitt, Loh & Showers
- 1970 IEEE EMC Symposium Record**
- "Specifications for Flexible Conduit for EMI Shielding"—W.J. Prysner.
- 1971 IEEE EMC Symposium Record**
- "Measuring Connector Shielding Effectiveness During Vibration"—Knowles & Brossier
 - "Cable Shield Effectiveness Testing"—Knowles & Olson
 - "Shielding of Cylindrical Tubes at Low Frequencies"—Johnson & Shenfeld
 - "The Measurement of Coaxial Cable Immunity to an Electromagnetic Field in the VHF Range"—E. Nano
- 1973 IEEE EMC Symposium Record**
- "Coupling of Transient Radiated Fields into Lines"—R.J. Mohr
 - "Interwire Coupling of Fast Risettime Signals"—C.E. Avio—C. Torinese
 - "Use of Magnetic Materials for Improvement of Screening Properties of Different Types of Cables"—L. Halme, J. Annanpalo
- 1974 IEEE EMC Symposium Record**
- "Sensitivity of Multiconductor Cable Coupling to Parameter Variations"—C.R. Paul
 - "Electromagnetic Induced Signals on Conduit Protected Cables"—D.J. Leverenz, J.T. Verdeyen, W. Croisant