

Reducing measurement uncertainty in EMC test laboratories

Calibrating the measurement equipment and the physical test site as a single entity can reduce measurement uncertainty and improve site-to-site correlation.

BRUCE ARCHAMBEAULT

IBM

Research Triangle Park, NC

COLIN E. BRENCH

Compaq Computer Corporation

Maynard, MA

Calculating measurement uncertainty has been the subject of many recent technical articles and presentations. There has been a lot of confusion about how to calculate a realistic and meaningful measurement uncertainty quantity. There is even more confusion about how to handle this uncertainty quantity.

A realistic consideration is how well a measurement correlates between two different test laboratories. Radiated emissions tests for commercial EMC standards are notorious for their poor correlation between laboratories. While some test facilities claim ± 2 dB, once everything is taken into account, the real number is more likely to be about ± 4 dB to greater than ± 7 dB! Such a large correlation deviation can easily cause one test facility to pass a given product, while another test facility will fail the same product. Clearly, this is undesirable, especially if a given product is likely to be tested in different facilities multiple times as various options are added.

It is necessary to develop a means of

ensuring that all sites are within tolerances acceptable for compliance testing and that data from one site to another can be correlated. To do this, additional correction factors must be introduced. While these are not (yet) acceptable for the preparation of data to show compliance, they do provide a high degree of confidence that all sites are operating properly and providing quality service.

SOURCES OF DEVIATION

Deviations are caused by a number of different sources. The quality of the test environment (OATS or anechoic room), the test process, and the accuracy of the measurement equipment all contribute to deviations. Some issues are technical in nature; for example, better calibration can reduce the deviation. Other issues are not technical and are more difficult to control.

The quality of the test environment is made by comparing the actual site to an ideal open area environment with an infinite metal ground plane. Reflections from the edge of the metal ground plane, reflections from walls (and anechoic materials), as well as reflections from other objects all contribute to the imperfection of the test environment. The site attenuation measurement quantifies the amount of "error" across the frequency range.

The site attenuation measurements

show that the site is within acceptable limits for the specific type of test being performed. However, regulatory agencies do not accept data which has been corrected for these variations when the data is submitted as evidence of compliance. A deviation of +3 dB at one site could be +3.5 dB at another. The uncertainty of the site is based on the accuracy of all the measurement equipment as well as the site itself.

Site deviations caused by the test process come from a number of factors, but mostly from the process used to optimize the emissions. Once a signal is under suspicion, the cables and peripherals are moved manually to find the combination which produces the highest emissions. Optimization is done in many different ways and at various measurement distances. For example, the turntable may be rotated, then the antenna elevation varied, or the antenna elevation may be varied, and then the turntable rotated.

For very high frequencies, the rotation and elevation variations must often be done in an iterative manner to find the true peak emission levels. Each process can easily result in a different combination of "highest" emissions. The result of this manual manipulation is very dependent on the skill of the person performing the task, and how long it

Since maximizing emissions is a personal skill, it is important to keep complete records of the tested system. Photographs are essential to provide a record of the exact configuration tested. While the regulatory agencies require only a few of the highest emission frequencies to be recorded in the test report, a much more complete emission list is essential to help ensure site-to-site correlation. If a different, but equally high, emission frequency is optimized during subsequent testing of a product, an entirely different test report could be generated, and little correlation would be seen between the tests. Having a complete data set and photographs enables this to be tracked.

MEASUREMENT EQUIPMENT ACCURACY

The accuracy of the measurement equipment is one of the primary sources of deviations in test site correlation. If it is assumed that the test facility is a "good" facility, the technicians are properly trained and the test process is optimized for accuracy, the measurement equipment becomes the most important parameter in the development of accurate site correction factors and the reduction of measurement uncertainty.

The measurement equipment at EMC test laboratories include EMI

An alternate method for increasing accuracy and minimizing uncertainty is to calibrate measurement systems comprising as many pieces of equipment as possible in a single calibration operation.

The current standard for calculating measurement uncertainty is the NIS81 from the National Physical Laboratory in England. Individual uncertainties are combined to find the overall measurement uncertainty. The highest individual contributors are the antenna calibration, the receiver specification, the antenna factor variation with height, and site imperfections.

It was decided that each of these individual contributors to measurement uncertainty would be evaluated separately, and calibrated (if possible) to reduce their contribution to the overall measurement uncertainty.

RECEIVER CALIBRATION

Accuracy is most important when measurements are made in the quasi-peak mode, since that is the ultimate measurement comparison to the regulatory limits. Three different receivers with quasi-peak measurement capabilities were available. They were the HP8568B/85650A spectrum analyzer QP detector combination, R&S ESVP/ESH-3 and the HP8546A EMI receiver. In addition to these receivers, the R&S ESVP/

The accuracy of the measurement equipment is one of the primary sources of deviations in test site correlation.

takes to find the maximum signal position. Test laboratories are under pressure to minimize test time and therefore severely limit the amount of time spent looking for the optimum signal level (at a cost of less-than-accurate results). The only way to reduce the test process deviation is to provide proper training to the technicians, and to allow sufficient time for them to find all the signals.

receivers and spectrum analyzers with peak and quasi-peak detectors, signal generators, power meters, network analyzers and various types of antennas. Each piece of equipment must be calibrated against a known standard to ensure accuracy. Because all uncertainties in these calibrations are basically added together, it becomes extremely important to minimize these uncertainties.

ESH-3 had the capability to measure in the "low noise" mode or the "low distortion" mode. Results from these two modes were different, and so they were treated as individual receivers.

The accuracy was measured by first calibrating a signal generator with a power meter. The power meter calibration accuracy was specified at 0.5 dB. This generator was




Figure 1. Measurement error for HP spectrum analyzers, quasi-peak (~0 dBm).




Figure 2. Measurement error for R&S receivers, quasi-peak (~0 dBm).




Figure 3. Difference between peak and quasi-peak for spectrum analyzers (~0 dBm).

then directly connected to the receivers and used as the source for all receiver measurements.

Figure 1 shows the measurement error for quasi-peak measurements for the HP8568B spectrum analyzer and HP85650A quasi-peak adapter when the input level was 0 dBm. A number of identical units were measured, and the variation between receivers was less than 2 dB. Figure 2 shows the same set of measurements for four different R&S ESVP/ESH-3 receivers operated in both the low noise (LN) and low distortion (LD) modes. In this case, the variation between receivers was about 2.5 dB.

A set of measurements was made to compare the peak and quasi-peak detectors in the receivers. Figures 3 through 5 show the deviation between the peak and quasi-peak measurements. Since a sine wave signal was used as the input, the resulting measurement should be identical for both detectors.

Since most EMI measurements are not made at 0 dBm, but at much lower signal levels, the above measurements were repeated at -62 dBm (45 dBμV). Figure 6 shows the results for the R&S ESVP/ESH-3 receivers in peak, QP/LN, and QP/LD modes. These results show the measurement accuracy worsens as the signal level is lowered. Figure 7 shows the results for the HP8546A receiver in both peak and QP modes at the low signal level. The difference in measurement accuracy showed a dramatic increase, and the graph scales had to be modified to show the results clearly. Another important point is that not only is the measurement accuracy important, but the spread of the results is also very important to measurement repeatability between different test laboratories. These results quickly pointed to an obvious way to reduce the measurement uncertainty contribution of the receiver, in this particular case, by carefully selecting the primary instrument for these measurements.

ANTENNA FACTOR VARIATION

It has been known for some time that the antenna factor of some antennas will vary as the antenna is moved closer or further from the metal ground plane in the test environment. Trying to predict the change in antenna factor is difficult. A series of measurements were made on biconical and log periodic antennas to evaluate this change in antenna factor.

The measurements were made using a HP network analyzer. The impedance of the antenna was measured at the antenna port itself, while the antenna height was varied. The antenna impedance is a key contributor to the change in the antenna factor.

Figures 8 and 9 shows the impedance change for a horizontal and vertically polarized biconical antenna relative to the 4-m height. The assumption is that the antenna impedance is as close to "free-space" antenna impedance as possible. The impedance variation is almost 6 dB for the horizontal polarization, and nearly 7 dB for the vertical polarization.

Figures 10 and 11 show the impedance change for a horizontal and vertically polarized log periodic antenna relative to the 4-m height. The assumption is again made that the antenna impedance is as close to "free-space" antenna impedance as possible. The impedance variation is about 2 dB for the horizontal polarization, and only 1 dB for the vertical polarization. There are two factors which help the log periodic antenna in this test. Electrically, it is much higher above the ground plane, and the strong inter-element coupling dominates over the ground plane effects. It can be clearly seen in the figures that the log periodic antenna is affected much less than the biconical antenna.

These tests were repeated with additional antennas (of the same type), and the results were consistent with the data in Figures 8 through 11. However, while the variation was




Figure 4. Difference between peak and quasi-peak (low noise) for R&S receivers (~0 dBm).




Figure 5. Difference between peak and quasi-peak for HP8546A EMI receiver (~0 dBm).




Figure 6. R&S receiver absolute measurement error at -62 dBm.




Figure 7. HP 8546A EMI receiver absolute measurement error at -62 dBm.




Figure 8. Biconical antenna factor (horiz.) variation over ground plane relative to 4-m height (Alltech 94455-1 SN #912).




Figure 9. Biconical antenna factor (vert.) variation over ground plane relative to 4-m height (Alltech 94455-1 SN #912).

consistent, the exact impedance at a given frequency could vary by 1 to 2 dB, as shown in Figure 12. This implies that any characterization of antennas with height must be done individually and not for a given antenna type.

Having a set of antenna factors for different heights could reduce the measurement uncertainty due to the antenna factor variation. While this initially sounds like a bookkeeping nightmare, it is much less hassle when the measurement system is automated. The antenna factor becomes a simple table lookup function.

OVERALL SITE ACCURACY

Establishing the overall measurement site accuracy is not a trivial task. The first requirement is to have an electric field source that is well-known in the environment in which it is used. A simple dipole antenna would have to be carefully calibrated in a metal ground plane environment, and then the repeatability and accuracy would still be doubtful as different signal generators are used as the source.

To overcome this problem, a spherical dipole source (SRS-2100)¹ was calibrated at the NIST open field site in Boulder, Colorado. Testing showed this unit to have a calibrated accuracy of about 0.5 dB, and a repeatability of about 0.25 dB. Having a total uncertainty of only 0.75 dB, this was considered the best possible electric field source for this type of site comparison.

The spherical dipole source was taken to a number of different test sites, all of which were fully approved. A series of measurements were made to determine how accurately each test site reported the field level. Figure 13 shows a typical result from a laboratory. The tests were repeated a number of times over a period of a few months to determine repeatability. As can be seen from Figure 13, the repeatability was very good. However, the absolute accuracy varied from 6 dB to +4 dB. This




Figure 10. Log periodic antenna factor (horiz.) variation over ground plane relative to 4-m height.




Figure 11. Log periodic antenna factor (vert.) deviation over ground plane relative to 4-m height.




Figure 12. Maximum variation of biconical antenna factor (vert.) over ground plane relative to 4-m height (Alltech 94455-1).

measurement included all the “normal” correction factors. That is, no special calibration of receivers, antennas (height), etc. was used.

Figure 14 shows a typical example of the variation between different measurement sites. Each site was measured using the same source. As can be seen in the figure, the variation from site to site could be as much as 4 dB. While this is very good, it does place a requirement for all products to have a minimum of a 4-dB guard band in order to ensure passing at any test facility.

The accuracy and consistency results are somewhat lower than desired. It is certainly undesirable to either over-design a product (due to reporting the emissions as higher than they really are), or under-design a product (due to reporting the emissions as lower than they really are). However, the overall accuracy (and therefore site-to-site consistency) can be improved using the data from these tests.

Figure 15 shows an example of a “site calibration factor” for a given test site based upon the average of a number of tests as shown in Figure 13. This site calibration factor includes all errors due to the site, the antennas and the test equipment, so it is therefore dependent on all of these being stable. If an antenna was changed, or a receiver changed, then the calibration factor would have to be recalculated. Figure 16 shows an example of the relative accuracy for a test laboratory using its site calibration factor. The accuracy has been improved, and of course, so has the site-to-site consistency once both sites use their individual site calibration factors.

REGULATORY ISSUES

The work presented here does go against a number of existing regulatory requirements. Site attenuation measurements are made to verify the suitability of a test site for compliance testing. It is not permissible, however, to correct measured data for any imperfections in the test site.

This leaves the potential to have data errors of up to ± 4 dB when compared to the ideal site.

A similar, though more complex, situation arises when considering the antenna factor behavior of the measurement antenna. It has been shown that the effective antenna factor can vary by over 2 dB with height. By using a matrix of antenna factors for height, polarization, and frequency, it is possible to increase both site-to-site correlation and overall accuracy. However, for regulatory compliance, a single antenna factor is required—theoretically the free space values—although the values are more often determined at a height of 4 m above the ground plane.

These two issues severely limit the application of site correction techniques. However, within a given group of test sites, there is no reason not to use this approach to ensure consistency and to create a tool to rapidly pinpoint when one site has a problem.

SUMMARY

The technique of calibrating both the measurement equipment and the physical test site as a single entity has been presented. Additionally, a key individual effect, the variation of effective antenna factor with height and polarization, has also been shown. These considerations provide a mechanism for reducing measurement uncertainty and improving site-to-site correlation.

Measurement uncertainty can be reduced, while increasing site-to-site measurement correlation, by increasing the accuracy of the measurement receiver. This can be accomplished either by selecting a more accurate receiver, or by additional calibration. Additional calibration of the antenna (vs. height) can also increase measurement accuracy. Finally, the overall measurement system can be calibrated (eliminating the need for individual calibrations) by using an accurate field source and combining all the various factors into one overall correction factor.




Figure 13. Test lab #1 horizontal polarized electric field deviation from NIST calibrated levels.




Figure 14. Comparison of different test labs average measurement deviation from NIST (horiz. polarization).




Figure 15. Lab #1 site calibration factor (for NIST accuracy), 1 May 98.

continued on page 200

section on large machines and installations. This is no surprise because this topic has been discussed in virtually every EMC meeting involving the EU EMC Directive since its inception.

According to Dave Imeson, Chairman of the European Commission Association of Competent Bodies (ECACB), "SLIM requires an update to the EMC Directive so first, Directorate General III (DGIII) needs to draw up legislation that implements the recommendations. Then it has to go through the whole process of rulemaking in Europe, the Commission, the European Parliament, and the Council of Ministers. Then, when all that is done, each member state has to change its national law. Hence a very long time, possibly 4 to 6 years."

In conclusion, it appears that there is considerable work required to bring the directive, guidance document and many of the specifications into line with the recommendations of the SLIM Team, but the essential requirements have not been changed.

GARY FENICAL is the EMC Technical Support Engineer at Instrument Specialties Co., Inc., in Delaware Water Gap, PA and has been with the firm for 16 years. Mr. Fenical has authored several articles on EMC requirements for medical devices, Mutual Recognition Agreements, and guidelines to meet the essential requirements of the EMC Directive. He has also authored several seminars on the EMC Directive, designing for EMC, and EMC requirements for medical devices which have been presented worldwide. He holds the patent for the invention of heat-treated beryllium-copper knitted wire mesh gasket. He has been invited to sit on the European EMCIT committee and has been a member of the Association of Competent Bodies Committees. Chairman of the SAE AE-4 Executive Committee on EMC, he is a member of the IEEE EMC Society, SMRI, and holds an FCC General Radiotelephone Licence (1st Class) with Ship RADAR Endorsement. (717) 424-8510, ext. 1177.

Reducing measurement uncertainty in EMC test laboratories ...

continued from page 184




Figure 16. Lab #1 horizontal polarization measurement deviation (from NIST), with site calibration factor.

While accurate EMI measurements are difficult, and large measurement uncertainties have been accepted in the past, most companies can no longer afford to place large guard bands on their products, effectively lowering the regulatory limits to ensure that the product passes. The only way to reduce the large guard bands used by most responsible companies is to increase the measurement accuracy. This increase in measurement accuracy (and reduction in measurement uncertainty) requires additional effort and calibration by vendors beyond that which is called for by regulatory agencies. However, the tools are available today, for those wishing to use them.

REFERENCE

1. Note: because of the level feedback provided in this unit, the dependence on the signal generator calibration was eliminated.

BRUCE ARCHAMBEAULT, PH.D. received his Ph.D. from the University of New Hampshire in 1997. His doctoral research was in the area of computational electromagnetics applied to real-world EMC problems. Having been with Digital Equipment Corporation and SETH Corporation, he recently joined IBM in Raleigh, North Carolina, where he is the lead

EMC engineer, responsible for EMC tool development and use on a variety of products. Dr. Archambeault has authored or coauthored a number of papers in computational electromagnetics, mostly applied to real-world EMC applications. He is currently an Associate Editor for the IEEE Transactions on Electromagnetic Compatibility and a Board of Directors member of the Applied Computational Electromagnetics Society. He is also a coauthor of the book titled "EMI/EMC Computational Modeling Handbook." (919) 486-0120.

COLIN E. BRENCH presently holds the position of Consultant EMC Engineer at Compaq Computer Corporation, Maynard, Massachusetts. With over 13 years at Digital (now Compaq), his EMC design work has encompassed a wide range of products, including small desktop systems, large multiprocessor servers and networking systems. Prior to joining Digital, he worked at Applicon for six years, where he was responsible for the EMC design of high-performance workstations and their associated servers. He is a coauthor of the book "EMI/EMC Computational Modeling Handbook" (Kluwer Academic, 1998) and has authored over 15 technical papers. He is a NARTE-certified EMC engineer, a member of the IEEE EMC Society and is active in TC-9 and ANSI ASC63 - SC1 committees. (978) 493-4642.